



Tinney's

Since
1957

SEPTIC SERVICE
& CONSTRUCTION

693 FULLER AVENUE, PENETANGUISHENE, ONTARIO L9M 2E8
PHONE: (705) 526-7269 FAX: (705) 526-7854



MAY 04TH, 2026

To Whom It May Concern,

This letter is to confirm that test holes were excavated at #67 Wozniak Rd, Penetanguishene, ON to confirm soil conditions. A T-time of 12 was assigned to the naturally existing silty sand.

This layer of suitable silty sand will act as a natural loading area and mitigate the requirements of a mantle.

Any septic system will need to be partially raised to maintain required clearances from the water table level in accordance with the Ontario building code. This means having a pump chamber and effluent pump.

A draft of a 2 bedroom, 2 bathroom, 210 sq metre building was provided. There is sufficient room to install a class 4 on-site septic system on this lot to service this house.

Any further questions can be directed to our office at 705-526-7269 or tinneys@live.com

Thank you,

Barrett Tinney

Barrett Tinney